



NOTE:
 ALL UNDERGROUND CONDUIT SHALL HAVE A TRACER WIRE AFFIXED TO THE OUTSIDE OF THE CONDUIT. THE TRACER WIRE SHALL BE NO. 10 STRANDED COPPER, WHITE INSULATION.

LEGEND
 □ ITS VAULT TO BE N48T OR PER PLANS.
 ⊙ IP DEVICE PER CURRENT CITY OF CLOVIS STANDARD.



CITY OF CLOVIS

DWG NO.
ITS-1

TYPICAL ITS CORRIDOR LAYOUT

REF. STD. SPECIFICATIONS:
 SECTION 82 & 86

APPROVED BY:

CITY ENGINEER

DATE:

[Handwritten signature]
 10/26/11

NO.	REVISED	BY	APPROVALS
	08-03-11	BGJ	CM <i>[Signature]</i>
	09-22-11	BGJ	DRU <i>[Signature]</i>
			PUB <i>[Signature]</i>
			OTHER _____
			OTHER _____
			OTHER _____

SCALE: NTS

DRAWN BY: JA

SHEET 1 OF 1