



NOTES:

1. CONST. EMBANKMENT W/MAX 10% SLOPE AWAY FROM SLAB.
2. COMPACT SUBGRADE TO 90% REL. COMPACTION PER CALTRANS T.M. 216.
3. CONCRETE SHALL BE CLASS 2, MEDIUM SWEAT FINISH. APPLY 1/8" WIDE X 1/2" DEEP SCORE LINES AS SHOWN.
4. WHEN SPECIFIED TO BE INSTALLED IN LIEU OF COMPLETE CONC. SLABS, BRICK PAVERS SHALL BE UNI-DECOR OR APPROVED EQUAL W/ BASKET WEAVE PATTERN.
5. BENCH SHALL BE 6-FT., VICTOR STANLEY, INC., CLASSIC SERIES CR-96, OR APPROVED EQUAL, MOUNTED TO SLAB PERMANENTLY USING METHODS APPROVED BY THE MANUFACTURER OR THE ENGINEER.
6. WHEN SPECIFIED TO BE INSTALLED, 36-GAL. TRASH RECEPTACLE SHALL BE VICTOR STANLEY, INC. IRONSITES SERIES S-42 OR APPROVED EQUAL. RECEPTACLE TO BE PERMANENTLY AFFIXED TO CONC. SLAB IN AN APPROVED MANNER.



CITY OF CLOVIS

DWG NO.
P-20

TRAIL REST STOP

REF.: STANDARD SPEC. SECTIONS 19, 73, & 90

APPROVED BY:	NO.	REVISED	BY	APPROVALS			SCALE: NTS
CITY ENGINEER DATE: <i>1/21/11</i>		01-21-11	BGJ	CM	OTHER		DRAWN BY: JA
				DRU	OTHER		SHEET 1 OF 1
				PUD	OTHER		