



NOTES:

1. IN STUBOUT LOCATIONS, A MINIMUM OF 36" OF EXCESS LOW VOLTAGE WIRE TO BE COILED AND STORED FOR FUTURE USE.
2. IN STUBOUT LOCATIONS, THE COMMON WIRE SHALL BE TERMINATED WITH A WATERPROOF INSULATING CONNECTOR. SEE STANDARD DRAWING FOR WIRE CONNECTOR.
3. SET TOP OF BOX EVEN WITH FINISH GROUND LEVEL IN TURF AREAS, 1" ABOVE GROUND LEVEL IN GROUND COVER AND SHRUB AREAS.



CITY OF CLOVIS

DWG NO.
P-5

BALL VALVE

REF: STD. SPECS
SECTION 21, LANDSCAPE
IRRIGATION SYSTEMS

APPROVED BY:	NO.	REVISED	BY	APPROVALS			SCALE: NTS
CITY ENGINEER		01-19-11	BGJ	CM	OTHER		DRAWN BY: JA
DATE: <i>1/24/11</i>				DRU	OTHER		SHEET 1 OF 1
				PUD	OTHER		