



NOTES:

1. SET TOP OF BOX EVEN WITH FINISH GROUND LEVEL IN TURF AREAS; 1" ABOVE GROUND LEVEL IN GROUND COVER AND SHRUB AREAS.
2. ALL PIPING AND FITTINGS SHALL CONFORM TO STD. SPEC. SECTION 21.5 "MATERIALS".
3. VALVE BOX SHALL BE CHRISTY FIBERLYTE, 11 1/4" X 17".
4. REMOTE CONTROL VALVE SHALL BE IRRITROL SERIES 100 OR 102.
5. CONTROL WIRING SHALL BE DIRECT BURIAL AWG-UF TYPE; "HOT" WIRE NOT SMALLER THAN AWG NO. 14; COMMON WIRE NOT SMALLER THAN AWG NO. 12.



CITY OF CLOVIS

REMOTE CONTROL VALVE

DWG NO.
P-7

STANDARD REF:
N.A.

APPROVED BY:		NO.	REVISED	BY	APPROVALS			SCALE: NTS
CITY ENGINEER	<i>[Signature]</i>		01-19-11	BGJ	CM	OTHER	---	DRAWN BY: JA
DATE:						DRU	OTHER	---
					PUD	OTHER	---	SHEET 1 OF 1