



NOTES:

1. HARDWARE SIZES (SERVICE SIZE) TO BE DETERMINED BY ENGINEER. ALL HARDWARE DOWNSTREAM OF BACKFLOW PREVENTER TO HAVE FLANGED CONNECTIONS.
2. DOMESTIC GATE VALVES TO BE SUPPORTED ON 2" PIPE SUPPORTS MOUNTED W/FLANGES ON CONCRETE PAD. ADDITIONAL SUPPORTS MAY BE REQUIRED ON LARGE SERVICES.
3. ENCLOSURE TO CONSIST OF CHAINLINK FENCE WITH DECORATIVE VERTICAL SLATS AND LOCKING GATE. SEE DRAWINGS ST-34, ST-34A.
4. ABOVE GROUND PIPE AND FITTINGS TO BE WRAPPED AND TIED WITH INSULATION AND BURLAP.



CITY OF CLOVIS

BOOSTER PUMP LAYOUT

DWG NO.
P-9

STANDARD REF:
N.A.

APPROVED BY:

CITY ENGINEER

DATE:

[Handwritten signature]
4/26/11

NO.	REVISED	BY	APPROVALS
	01-28-11	BGJ	CM DRU PUD
			OTHER OTHER OTHER

SCALE: NTS

DRAWN BY: JA

SHEET 1 OF 1