

CASE 2
NEW WATER MAIN (SEE NOTE 2)

NOTES:

1. ZONES "P" ARE PROHIBITED ZONES, NO VARIANCES OR SPECIAL CASES.
2. A NEW WATER MAIN CROSSING A PIPE CARRYING NOT-POTABLE FLUIDS SHALL BE CONSTRUCTED NO LESS THAN 45 DEGREES TO THE PIPE BEING CROSSED.






CITY OF CLOVIS

DWG NO.
S-9

SEWER AND WATER MAIN CROSSING CONSTRUCTION SEPARATION

REF. STD. SPECIFICATIONS
SECTION 64

APPROVED BY:	NO.	REVISED	BY	APPROVALS	SCALE: NTS
CITY ENGINEER 		03-13-09	BGJ	CM 	DRAWN BY: BGJ
	DATE: 6/29/09			DRU 	SHEET 1 OF 1
				PUD 