



NOTES:

1. THIS BACKFILL METHOD IS REQUIRED FOR UTILITIES POTHOLES 9" DIAMETER OR LESS, OR MAXIMUM DIMENSION IN ANY DIRECTION OF 9" OR LESS, OR ANY POTHOLE DIRECTED BY THE ENGINEER TO BE BACKFILLED BY THIS METHOD.
2. POTHOLES WITH DIMENSIONS GREATER THAN 9" SHALL BE BACKFILLED PER THE STANDARD DRAWING ST-20 FOR TRENCH BACKFILL AND SURFACE RESTORATION.
3. SLURRY CEMENT BACKFILL SHALL CONFORM TO SECTION 19-3.062 OF THE STATE STANDARD SPECIFICATIONS.
4. TEMPORARY TRENCH RESURFACING SHALL CONSIST OF A MINIMUM OF 4" COLD MIX AND SHALL BE REQUIRED WHENEVER THE STREET IS TEMPORARILY OPENED TO TRAFFIC. ALL TEMPORARY MATERIAL SHALL BE COMPLETELY REMOVED PRIOR TO FINAL PAVING.



CITY OF CLOVIS

DWG NO.
ST-21

UTILITY POTHOLE BACKFILL

REF.:
STD. SPECIFICATIONS
SECTION 8-15

APPROVED BY:	NO.	REVISED	BY	APPROVALS	SCALE: NTS
		05-12-09	BGJ		CM
CITY ENGINEER		01-13-11	BGJ	DRU	SHEET 1 OF 1
DATE: <i>7/29/11</i>		02-15-11	BGJ	PUD	