



**NOTES**

1. PROVIDE EXTENSIONS AS NECESSARY.
2. INSTALL TRACER WIRE LEAVING A 12" MIN. LEAD INSIDE OF G5 BOX.
3. VALVE TO TURN COUNTERCLOCKWISE TO OPEN.
4. RISER LENGTH TO BE DETERMINED BY FIELD CONDITIONS.
5. VALVE NUT TO BE CENTERED IN RISER.
6. RISER TO BE PLUMB.

SECTION A-A



# CITY OF CLOVIS

DWG NO.

## W-1

## WATER VALVE

REF. STD. SPECIFICATIONS SECTION 66

APPROVED BY:	NO.	REVISED	BY	APPROVALS	SCALE: NTS
CITY ENGINEER		11-23-09	BGJ	CM DRU PUD	DRAWN BY: JA
	DATE: 1/26/10	07-28-09	BGJ		
					SHEET 1 OF 1