



**NOTES:**

1. CONTRACTOR SHALL FURNISH AND INSTALL ALL ITEMS AS APPROPRIATE AS LISTED ON STD. DWGS. W-5, W-5A, W-6, W-6A.
2. WATER METER TO BE FURNISHED AND INSTALLED BY CITY.
3. WATER SERVICE AND METER BOX INSTALLATION SHALL BE INSPECTED AND APPROVED BY CITY PRIOR TO SIDEWALK INSTALLATION.
4. NO WATER SERVICE IN DRIVEWAY APPROACH OR WING WILL BE ACCEPTED.
5. ALL MATERIALS FURNISHED SHALL BE AS NOTED, OR CITY APPROVED EQUAL.
6. SEE STD. DWGS. W-5 AND W-6, W-6A FOR SPECIFICATIONS.
7. ALL GALVANIZED PIPE AND FITTINGS SHALL BE WRAPPED AND FLETCHER COATED.
8. ANGLE METER STOP TO BE MUELLER 110 COMPRESSION B-24276N BALL VALVE OR CITY APPROVED EQUAL.
9. RETROFIT MANIFOLD REQUIRES PRIOR APPROVAL FROM PUBLIC UTILITIES DEPARTMENT.



# CITY OF CLOVIS

## 1" & 2" COMMERCIAL RETROFIT MANIFOLD WATER SERVICE LAYOUT

DWG NO.  
**W-6B**

REF. STD. SPECIFICATIONS  
SECTION 66

APPROVED BY:  
  
CITY ENGINEER  
DATE: 1/20/10

NO.	REVISED	BY
	11-24-09	BGJ
	07-28-09	BGJ

APPROVALS  
CM *[Signature]*  
DRU *[Signature]*  
PUD *[Signature]*

SCALE: NTS  
DRAWN BY: RE  
SHEET 1 OF 1