



CASE 2
NEW WATER MAIN (SEE NOTE 2)

NOTES:

1. ZONES "P" ARE PROHIBITED ZONES, NO VARIANCES OR SPECIAL CASES.
2. A NEW WATER MAIN CROSSING A PIPE CARRYING NOT-POTABLE FLUIDS SHALL BE CONSTRUCTED NO LESS THAN 45 DEGREES TO THE PIPE BEING CROSSED.



CITY OF CLOVIS

DWG NO.	
---------	--

S-9

SEWER AND WATER MAIN
CROSSING CONSTRUCTION SEPARATION

REF. STD. SPECIFICATIONS
SECTION 64

APPROVED BY:

NO.

REVISÉD

BY

APPROVALS

SCALE: NTS

CITY ENGINEER

03-13-09

BGJ

CM

DRAWN BY: BGJ

DATE: _____

6/29/09

Abstract

PUE

SHEET 1 OF 1

SHEET 1 OF 1