



**NOTES:**

1. CURB RETURN, GUTTER AND VALLEY GUTTER TO BE POURED MONOLITHICALLY.
2. EXPANSION JOINT MATERIAL SHALL BE 1/4" THICK PREMOLDED JOINT FILLER CONFORMING TO REQUIREMENTS OF ASTM DESIGNATION D 1751.
3. SURFACE SHALL BE ROUGH BROOM FINISH.
4. CONCRETE SHALL BE CLASS I OR 2.
5. VALLEY GUTTER SUBGRADE SHALL BE COMPACTED TO 95%.



# CITY OF CLOVIS

DWG NO.  
**ST-10**

## CONCRETE VALLEY GUTTER

REF.:  
STD. SPECIFICATIONS

APPROVED BY:  CITY ENGINEER 2020.12.10 DATE: 15:34:03-08'00'	NO.	REVISED	BY	APPROVALS	SCALE: NTS
	2	05-29-12 04-13-17 05-04-20	PAA CGV CGV	CM DRU PUD	DRAWN BY: JA SHEET 1 OF 1