



CITY *of* CLOVIS

BUILDING DEPARTMENT

1033 FIFTH STREET • CLOVIS, CA 93612

Residential Roof Mounted Photovoltaic Submittal Requirements

1) Permit application. 2022 CRC R106.1

- An accurate description of work.
- Project address.
- Owner information.
- Contractor information.
- Valuation.
- Signed by Applicant or Applicant's Authorized Agent.

2) Construction Documents - 2022 CRC R106.1

a) Plan Set Cover Sheet. 2022 CRC R106.2

- Project address.
- Vicinity Map.
- Provide the owner's name and phone number.
- Name and address of designer.
- Contractor information.
- Scope of work to be performed.
- List of all equipment or system components to be installed: (PV Modules, Inverters, Main panel Upgrades, Sub Panels, Combiner Panels, Load Centers, Energy Storage Devices, Gateways, Rapid Shutdown Devices, Optimizers, Existing PV Systems, Etc.)
- List of all current and applicable California codes.
- Provide an accurate Sheet index.
- Provide a Legend for all symbols, abbreviations, etc.

b) Site Plan – 2022 CRC R106.1

- Show the lot with property lines and the footprint of existing structures.
- House location on the parcel.
- Show and label the location of all equipment and system components. (PV Modules, Inverters, Main panel Upgrades, Sub Panels, Combiner Panels, Load Centers, Energy Storage Devices, Gateways, Rapid Shutdown Devices, Optimizers, Existing PV Systems, Etc.)
- The streets are shown and labeled.
- Include a North arrow (Compass orientation).

- c) Roof (These requirements apply to roof assemblies with a slope greater than 2:12)**
- **Show Fire Setbacks** (Setback between horizontal ridges and PV arrays.) **2022 CRC R324.6 and R324.6.1**
 - (1) Setback dimensions.
 - (2) Provide the total percentage of the plan view of the rooftop that the photovoltaic array(s) cover.
 - (3) Is the residence equipped with fire sprinklers?
 - **Show Access Pathways** (Pathway from roof lowest edge to Fire Setbacks on the same plane, adjacent plane, or straddling same and adjacent planes.) **2022 CRC R324.6, and R324.6.2**
 - (1) 2 Access Pathways will be required with a minimum width of 36".
One of the Access pathways must be from the street side of the residence. (In front of the fence.)
 - (2) Shall be located in areas capable of supporting firefighters accessing the roof.
 - (3) Shall be located in areas with minimal obstructions.
 - **Emergency Escape and Rescue Openings. 2022 CRC R324.6.3**
 - (1) PV modules shall not be installed below such openings.
 - (2) A path no less than 36" shall be provided to such openings.

d) Attachment 2022 - CRC R106.1

- Show points of attachment within the array on rafters/trusses. Ensure the maximum span and cantilever indicated in the data sheet are met.
- Show an expanded view of attachment and the build-up of roofing, attachment mechanism, flashing, and sealing.

e) Electrical - 2022 CEC

- Show a complete electrical one-line or three-line diagram.
- Provide equipment schedule with respective ratings/electrical characteristics.
- Show rating of all overcurrent devices. Provide electrical calculations supporting the proposed loads on the overcurrent protection devices. 120% rule, CEC 705.12 (B) (2) (3) (b): Point of connection.
- Show all conduit sizes and types. Provide electrical calculations supporting the conduit sizes and types.
- Provide conductor schedule, including sizes, types, and quantities.
- Is the Main Service Panel existing, or will the existing main service be upgraded?
- Provide electrical calculations supporting the proposed derating of the Main Service Breaker.
- Provide information describing any existing interconnected power sources (Photovoltaic systems, generators, turbines, etc.), and indicate if they are either Non-rapid shutdown devices or Rapid shutdown device compliant. Provide calculations and one-line drawings
- Energy storage systems.

f) Labeling - 2012 CEC

- Show all applicable labeling in color.
- Directory placard.
 - (1) Show the location of the array(s), equipment, and point of connection.
 - (2) Show dotted lines around exiting arrays that do not conform to the Rapid Shut Down requirements of 2022 CEC.

g) Data Sheets - 2022 CRC R106.1

- Inverters/Micro-inverters.
- PV modules.
- RSD Devices/Optimizers.
- Racking (Please provide the basic datasheet, not the complete installation guide.)
- Attachment system.
- Array bonding.
- Combiner panels.
- Main Service Panels/Sub Panels.
- Monitoring systems.
- Batteries/Energy storage.
- Transfer switches.
- Specialty Electrical Equipment (Green Meter Adapters, EV chargers, etc.)
- Generators, turbines, etc.

h) Addendums, revisions, and resubmittal documents.

- A full description of the changes on the plans for all revisions and addendums submittals is required.
- A cloud or delta will be at every change on the plans set, and any corrections addressed on all addendums, revisions, and resubmittal plans.

i) Energy Storage System (ESS), “ESS Ready” for new construction. 2022 California Energy Code Section 150.0 (s), 2022 California Residential Code Section 328 Energy Storage Systems, and the 2022 California Electrical Code Article 706.

(s) **Energy storage systems (ESS) ready.** All single-family residences that include one or two dwelling units shall meet the following. All electrical components shall be installed in accordance with the *California Electrical Code*:

1. At least one of the following shall be provided:
 - A. ESS ready interconnection equipment with a minimum backed-up capacity of 60 amps and a minimum of four ESS-supplied branch circuits, or
 - B. A dedicated raceway from the main service to a panelboard (subpanel) that supplies the branch circuits in Section 150.0(s)(2). All branch circuits are permitted to be supplied by the main service panel prior to the installation of an ESS. The trade size of the raceway shall be not less than 1 inch. The panelboard that supplies the branch circuits (subpanel) must be labeled “Subpanel shall include all backed-up load circuits.”
2. A minimum of four branch circuits shall be identified and have their source of supply collocated at a single panelboard suitable to be supplied by the ESS. At least one circuit shall supply the refrigerator, one lighting circuit shall be located near the primary egress and at least one circuit shall supply a sleeping room receptacle outlet.
3. The main panelboard shall have a minimum busbar rating of 225 amps.
4. Sufficient space shall be reserved to allow future installation of a system isolation equipment/transfer switch within 3 feet of the main panelboard. Raceways shall be installed between the panelboard and the system isolation equipment/transfer switch location to allow the connection of backup power source.

1. ESS equipment will be listed, and all specifications for the ESS will be provided.
2. Individual units will be separated by less than 3 ft. unless documentation shows that it may be closer per the California Fire Code.
3. Approved locations: Detached garages and accessory structures, attached garages, outdoors or on the exterior wall, 3 ft from doors and windows directly entering the Dwelling unit,
4. Enclosed Utility closets, basements storage, or utility spaces within the dwelling unit with finished or non-combustible walls and ceilings, unfinished walls, and ceilings shall be provided with a 5/8" type X Gypsum wall-board.

Note: may not be installed in bedrooms, closets, or spaces opening directly into the sleeping room.

Energy rating. Individual units shall have a maximum rating of 20 kWh and the aggregate rating not to exceed the following:

1. 40 kWh in utility closets, basement, and storage spaces
2. 80 kWh in an attached or detached garage and detached accessory structures.
3. 80 kWh on exterior walls
4. 80 kWh outdoors on the ground.

Fire detection in dwelling units, attached garages, and basements. When required, a listed heat detector shall be installed. A smoke alarm protects it.

Protection from impact per sections R328.8 and R328.8.1 of the 2022 California Residential Code.

Ventilation for indoor ess that produces hydrogen or other flammable gases. Per the 2022 California Mechanical Code.

ESS that has the potential to release toxic and highly toxic gases during normal use shall not be installed within Group R-3 or R-4 occupancies.