



Clovis Fire Department

Standard # 1.10

Electric Security Fence Requirements

Emergency Access shall include all of the following:

1. An electrical disconnect device secured by a Knox box or a Best model #21B722-L Police/Fire Padlock with a CX-1 core for emergency access shall be provided at a location approved by the Fire Department. Best model locks or keyways may be purchased through the following dealers:

Sierra Lock & Glass
1560 N. Palm
Fresno, CA 93728
559-266-9421

A1 Lock & Key
515 4th St
Clovis, CA 93612
559-298-5625

2. The disconnect device shall include an LED pilot light to indicate the status of power to the electric fence.
3. The emergency access disconnect device shall be located outside of the primary drive gate entrance of the property and shall not be obscured in any manner from the street/private driveway access.
4. Approved signs stating the identification of such switches/controls in addition to informational instructions as to how to disable the electrical system shall be installed to the satisfaction of the Fire Department.
5. In the event that access by the City of Clovis Fire Department and/or Police Department is required due to an emergency or urgent circumstances and the emergency access disconnect device is absent or non-functional and no authorized property personnel is present to disable the electric fence, City of Clovis Fire or Police personnel shall be authorized to disable the electric fence in order to gain access to the property. All applicants issued Building permits to install or use an electric fence as provided in this review agree to waive any and all claims for damages to the electric fence against the City of Clovis and/or its personnel under such circumstances.
6. Submit plans including equipment specifications, signage, and scaled site plan to and obtain permit from the Clovis Fire Prevention Bureau for the installation of the electric fence.

7. Prior to energizing the electric fence, the fence shall be inspected and approved by the Clovis Fire Prevention Bureau. Inspections may be scheduled by calling 559/324-2278
8. Contact the City of Clovis Planning and Development Services Division for any other additional required submittals and approvals.

The electrified fence shall remain deactivated during normal business hours when the main gate to the property is open.

Plans to be submitted for review once there is an approved site plan to Planning Department for an electrical permit and both electrical and Fire Department review and permit fee.