



CLOVIS FIRE DEPARTMENT

Standard #2.3

Water Flow for Sprinkler System

Whereas the City of Clovis Water Department is the sole water purveyor for all building properties within its city limit. The following water supply information is the recognized standard water-flow data for the City of Clovis. This information is provided for the purpose of designing and installation of fire sprinkler systems.

Static: 45 PSI
Residual: 35 PSI
GPM: 1800 GPM

Exception: Under special situations, the Clovis Fire Department reserves the right to require testing of the water supply in the general area of a project, to verify or determine the actual available water flow. The water supply flow testing shall be conducted by an approved third-party entity and will require an Operational Permit for the use of the fire hydrants in conformance with C.M.C. 6.5.109. All water-flow testing shall be done in the presence of a Clovis Fire Official. When this testing is required, the **most regulating** water-flow data will be used.

Regarding:

Location:

Date:

To Interested Parties,

- The above project site has been evaluated and found to be included in the water-flow criteria of Clovis Fire Standard #2.3. If you should have any questions please feel free to call the Clovis Fire Department.
- The above project site will need fire hydrant testing of the specific area as determined by the Clovis Fire Department. Please call the Clovis Fire Department for more specific information.

Clovis Fire Department
1233 Fifth Street
Clovis, CA 93612
559-324-2200